



No. F6/DFS/MS/School/W2/2023/108

Dated:- 16/02/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Richmond Global School Located at NS Road, Mianwali Nagar, Paschim Vihar, New Delhi-110087 comprised of Ground + 03 Upper Floors only owned/occupied by Mata Krishnawanti Memorial Educational Society (Reg.), was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/2019/1640 Dated 19.08.2019. The said premise was re-inspected by the officer concerned of this department on 09.02.2023 in the presence of Sh. Jai Bhagwan Dagar (Caretaker) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 16/02/2023 for a period of three years, in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010, printed below.

Issued on 16/02/2023 at New Delhi by.

(Dharampal Bhardwaj)  
Chief Fire Officer

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Richmond Global School, NS Road, Mianwali Nagar, Paschim Vihar, New Delhi-110087

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry

Principal  
Richmond Global School  
NS Road, Mianwali Nagar, Opp. Inder Enclave  
Paschim Vihar, New Delhi-110087